

CERTIFICATE OF ANALYSIS

R-134A

Date: 12 July 2020

SPECIFICATION (INCLUDE THE CHEMICAL AND PHYSICAL PROPERTIES):

ITEMS	REQUIREMENT	TESTING RESULTS
PRODUCT APPEARANCE	Visually clean	Pass
PARTICULATES/SOLIDS	Visually clean	Pass
PURITY (%)	99.50%	99.94%
MOISTURE (%)	10ppm	9ppm
ACIDITY (% AS HCL)	1ppm	0.1ppm
CHLORIDE, MAXIMUM	No visible turbidity	Pass
EVAPORATING RESIDUE, MAXIMUM	0.01%	0.0006%
NON-CONDENSABLE GAS, MAXIMUM	1.50%	0.94%
HALOGENATED UNSATURATED HYDROCARBON, MAXIMUM	No Standard	0.0008%



THE ABOVE PRODUCT PASS OUR ENTERPRISE STANDARD.

