

## CERTIFICATE OF ANALYSIS

# R-22

Date: 21 August 2020

### SPECIFICATION (INCLUDES THE CHEMICAL AND PHYSICAL PROPERTIES)

ITEMS	REQUIREMENT	TESTING RESULTS
APPEARANCE	COLORLESS AND TRANSPARENT	COLORLESS AND TRANSPARENT
ODOR	ODORLESS	ODORLESS
PURITY (%)	≥ 99.90	99.94
MOISTURE (%)	≤0.0010	0.0006
RESIDUE (%)	≤0.010	0.0005
ACIDITY (% AS HCl)	≤0.0001	UNDETECTED
NON ABSORBABLE GAS VAPOR PHASE (%)	≤1.5	0.5
CHLORIDES, % BY VOLUME	PASS	PASS
APPEARANCE	COLORLESS AND TRANSPARENT	COLORLESS AND TRANSPARENT
ODOR	ODORLESS	ODORLESS
PURITY (%)	≥ 99.90	99.94
MOISTURE (%)	≤0.0010	0.0006



THE ABOVE PRODUCT PASS OUR ENTERPRISE STANDARD.

